

FIRE PROTECTION INFORMATION:

- Fire extinguishers, hose cabinets, fire hose standpipe connections and other fire appliances shall be maintained, clearly visible and accessible at all times. A minimum of 1 metre clearance shall be provided with full frontal access to firefighting equipment.
- Vehicles, RV's, trailers and booths that include tents, canopies and/or other structures inside a building having between 9.3 m² (100 ft.²) and 27.9 m² (300 ft.²) of roof, ceiling or other obstruction shall be provided with a listed single smoke alarm.
- Vehicles, RV's, trailers and booths that include tents, canopies and/or other structures inside a building having between 9.3 m² (100 ft.²) and 27.9 m² (300 ft.²) of roof, ceiling and/or other obstruction with a source of ignition shall be provided with a listed single smoke alarm plus a 2A-10BC fire extinguisher.
- Any booth utilizing cooking and/or warming appliances shall have a 2A-10BC extinguisher. A "K" Class fire extinguisher is required if oil and/ or fats are being used or if grease laden vapours are produced.
- A 2A-10BC fire extinguisher rating shall be located within 7.5 m of a propane cylinder.
- All extinguishers must be listed, labelled and inspected annually by accredited service provider