

Fuelled Equipment 20 Division B, Part 2, Article 2.12.1.8. is repealed and the following substituted:

**“2.12.1.8. Fuelled Equipment**

1) In a Group A or E occupancy, as established by the National Building Code, no person shall sell or display a fuel powered vehicle or fuel powered piece of equipment except where:

- a) the fuel tank of the vehicle or piece of equipment is filled with less than half of the fuel tank’s capacity;
- b) the covered mall or store is equipped with a sprinkler system installed in conformance with the National Building Code;
- c) the battery in the vehicle or piece of equipment has been disconnected while the vehicle or equipment is being displayed; and
- d) the caps for fuel tanks have been locked or secured against tampering

**Fuel-Fired Industrial Trucks**

21 The following clause is added after Division B, Part 3, Clause 3.1.3.2.3) d): “and

e) the industrial truck is parked at a location approved by the authority having jurisdiction.”

**Outdoor Storage**

22 Division B, Part 4 is modified by adding the following article after Article 4.2.4.6.:

**“4.2.4.7. Outdoor Storage**

- 1) Not more than 50L of flammable liquids and combustible liquids, of which not more than 30L shall be Class I liquids, are permitted to be stored on a residential property outside a dwelling unit or associated garage or shed.”

**Water-Based Fire Protection Systems**

23 Division B, Part 6, is modified by adding the following after Article 6.4.1.1.:

**6.4.2. Hydrants**

**6.4.2.1 Maintenance**

- 1) No person shall erect, place, allow or maintain a fence, shrub, tree or other object within one metre of a hydrant.
- 2) No person shall alter the appearance or colour of a hydrant owned by the City of Regina.”