

Vehicle Guidelines (Gasoline, Diesel, Electric)

1. Motor vehicles or gasoline/diesel-powered equipment on display must be equipped with lock-on type gasoline tank caps and batteries are to be disconnected. Gasoline tanks must not be filled beyond the $\frac{3}{4}$ mark in order to allow for expansion of product. Vehicles unable to be equipped with lock-on type caps must have caps sealed/taped in a manner acceptable to the Fire Department.
2. Running of display vehicles during exhibit is prohibited unless approved by Event Operations.
3. Shows requiring vehicles to run as part of a performance or contest must fuel vehicle outdoors using approved safety containers.
4. Propane charged cylinders are not permitted on self-propelled vehicles or trailers on display inside buildings.
5. If at any time an Event Operations Representative deems that equipment is being operated in a manner dangerous to public safety, he shall cancel the privilege of the exhibitor concerned.
6. Electric Vehicles must be in good working order - damaged Lithium-ion batteries may suffer from thermal runaway and in extreme cases this can lead to combustion.
7. The Electric Vehicles can **not** be on charge while in the building.
8. Fire extinguisher (ABC) must be in the booth and a person present that knows how to use the extinguisher. (PASS)
9. When electric, gasoline, or diesel vehicles are in the building, there must be an overnight guard to monitor the vehicle(s). The guard must be aware of where the fire extinguisher is located and trained in the use of fire extinguishers and
10. If gasoline, diesel, or electric vehicles are being stored in the building overnight, security is mandatory to monitor the site after hours. The security guard must have access to a fire extinguisher and be trained in the use of the fire extinguisher.

All events are subject to site inspection and further mandates may be communicated onsite.